

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.**

No. 751211520100007752F

Date: 20/06/2021

It is certified that an inspection team headed by Sh. Chandra Dev  
Singh, Water Section Incharge (Name of Officers  
with designation) from AGSS Analytical & Research Lab Pvt Ltd (Name of  
Department/Office) inspected the Rawalpindi S.D.S.S School Old Sabzi  
mandi, Malkagang Road Delhi (1207145) (Name & Address of  
the School) on \_\_\_\_\_ and found that the Rawalpindi S.D.S.S School  
Old Sabzi mandi, Malkagang Road Delhi - 07 (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T Govt.

The above valid for a period of 6 month.

Signature with Seal : \_\_\_\_\_

Name

: Chandra dev Singh

Designation

: Water (Section Incharge)


To

Rawalpindi Sanatan Dharma  
Sr. Sec. School, Old Sabzi Mandi  
Malkagang, Road Delhi - 07

(Name & Address of the institution)

Abhishek  
Manager

**Rawalpindi S.D. Sr. Sec. School**  
**Subzi Mandi, Delhi-71**



W  
pu  
School Incharge

**Rawalpindi Sanatan Dharma Sr. Sec. School**  
**(Recognised & Aided by Govt. NCT of Delhi)**  
**Subzi Mandi, Delhi-110007**



# AGSS ANALYTICAL AND RESEARCH LAB (P) LTD.

(Accredited as per ISO/IEC 17025 : 2017, Recognised by FSSAI, MoEF&CC and Directorate of Ayush)

C-37/2, 3rd & 4th Floor, Lawrence Road, Industrial Area, Delhi-35

Ph.: 011-45022985, 9311654060

E-mail: agsslabs@gmail.com, support@agsslabs.com Web.: www.agsslabs.com Certificate No. TC-12115



DIN: L78200DL2016PTC300483 GST: 07AAOCA4142Q126

Format No.: AGSS-GSR-024

## TEST REPORT

Page No.: 1 of 2

Issued to : Rawalpindi Sanatan Dharam Sr. Sec. School Old Subzi Mandi Malka Ganj Road, New Delhi 110007	ULR No. : TC121152400007752F Report No. : AGSS/WT/24061400037 Sample Issue Date : 14/06/2024 Report Issue Date : 20/06/2024
---	--

Name of The Product : Drinking Water	Sample Received Date : 14/06/2024
Product Description : Colourless Liquid	Analysis Starting Date : 14/06/2024
Batch No./Lot No. : NA	Analysis Completion Date : 20/06/2024
Date of Manufacturing : Not specified	Date of Sampling : -
Date of Expiry : Not specified	Quantity Received : 3 Ltr
Packing Condition : Plastic Bottle	Environment Condition : Ok
Location : NA	Sampling Method : NA
Sample Received / Collected By : Anil (AGSS Lab Rep.)	Sampling By : NA
Testing Required : Chemical & Microbiological Test	
Others specification : Source of Water- Supply Water	

## TEST RESULT

S.No.	Test Parameters	Units	Results	Requirement as per IS:10500:2012		Method of Testing
				Acceptable Limit	Permissible Limit	
Chemical Parameters:-						
1	Colour	Hazen	<1.0	5 Max	15 Max	IS:3025 (Part-4) : 2021 (Visual Comparison Method)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025 (Part-5) : 2018
3	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025 (Part-8) : 1984
4	pH Value	-	7-14	6.5-8.5	No Relaxation	IS:3025 (Part-11) : 2022 (Electrometric Method)
5	Turbidity, NTU	NTU	<1.0	1.0 Max	5.0 Max	IS:3025 (Part-10) : 1984 (Nephelometric Method)
6	Total Dissolved Solids mg/L	mg/L	108.0	500 Max	2000 Max	IS:3025 (Part-16) : 2023 (Gravimetric Method)
7	Total Hardness (as CaCO <sub>3</sub> )	mg/L	38.1	200 Max	600 Max	IS:3025 (Part-21) : 2009 (EDTA Titrimetric Method)
8	Sulphate (as SO <sub>4</sub> )	mg/L	2.5	200 Max	400 Max	IS:3025 (Part-24-Sec-1) : 2021 (Turbidity Method)
9	Calcium (as Ca) mg/L	mg/L	11.8	75 Max	200 Max	IS:3025 (Part-40) : 2022 (EDTA Titrimetric Method)
10	Magnesium (as Mg) mg/L	mg/L	2.0	30 Max	100 Max	APHA 24th Edd. 3500-Mg-B (Calculation Method)


T: 24061400037-1



*Nikhil Gupta*  
Nikhil Gupta  
Technical Manager  
Checked by

*Soraj Gautam*  
Soraj Gautam  
Microbiologist  
Authorized Signatory

*Dr Shival Singh*  
Dr Shival Singh  
Director Technical  
Authorized Signatory



*Abhinav*  
Manager

*Dr*  
School Incharge

Rawalpindi S.D. Sr. Sec. School  
Subzi Mandi, Delhi-71

Rawalpindi Sanatan Dharam Sr. Sec. School  
(Recognised & Aided by Govt. NCT of Delhi)  
Subzi Mandi, Delhi-110007

NOTE: (1) The laboratory is not responsible for content of report. (2) The above result pertain only to the sample tested and applicable parameters. (3) Test report shall not be reproduced except in full, without written approval of the laboratory. (4) This test report shall not be reproduced wholly or in part, and used as an evidence in the court of law without written approval of M/S AGSS. (5) The sample will be stored up to 21 days from the date of issue of test



# AGSS ANALYTICAL AND RESEARCH LAB (P) LTD.

(Accredited as per ISO/IEC 17025 : 2017, Recognised by FSSAI, MoEF&CC and Directorate of Ayush)

C-372, 3rd & 4th Floor, Lawrence Road, Industrial Area, Delhi-35  
Ph.: 011-45022985, 9311654060

E-mail: agsslabs@gmail.com, support@agsslabs.com Web.: www.agsslabs.com  
Formal No. AGSS/03/2024 Page No. 2 of 2



CIN: U73200DL2016PTC300483 GST: 07AAOCA142Q1Z6

Issued to: Rawalpindi Sanatan Dharam Sr. Sec. School Old Subzi Mandi Maika Ganj Road, New Delhi 110007	ULR No. : TC121152400007752F Report No. : AGSS/WT/24061400037 Sample Issue Date : 14/06/2024 Report Issue Date : 20/06/2024
--	--

S.No.	Test Parameters	Units	Results	Requirement as per IS:10500:2012		Method of Testing
				Acceptable Limit	Permissible Limit	
11	Fluoride (as F) mg/L	mg/L	<0.1	1.0 Max	1.5 Max	APHA 24th Edd.4500-F-D (Spadns Method)
12	Chloride (as Cl) mg/L	mg/L	11.9	250 Max	1000 Max	IS:3025 (Part-32):1988 (Argentometric Method)
13	Total Alkalinity (as CaCO <sub>3</sub> ), mg/L	mg/L	28.0	200 Max	600 Max	IS 3025 (Part-23) 1986 (Indicator Method)
14	Iron (as Fe) mg/L	mg/L	BLQ(0.1)	0.3 Max	No Relaxation	AGSS/CHEM/SOP-ICPMS/03
15	Residual free Chlorine, mg/L	mg/L	<0.2	0.2 Max	1.0 Max	IS :3025 (Part-26):2022 (Colorimetric Method Using DPD)
Microbiological Parameter:						
16	Coliform	/100ml	Absent	Absent	-	IS:15185:2016
17	e. coli	/100ml	Absent	Absent	-	IS:15185:2016

Remarks: 1) The Tested Sample Conforms as per IS: 10500: 2012, with respect to above test only.  
Note: 1) BLQ=Below Limit of Quantification. 2) Figure in bracket indicate limit of quantification  
\*\*\*End of Report\*\*\*

*Abhinav*  
**Manager**  
Rawalpindi S.D. Sr. Sec. School  
Subzi Mandi, Delhi-74

*D*  
**School Incharge**  
Rawalpindi Sanatan Dhama Sr. Sec. School  
(Recognised & Aided by Govt. NCT of Delhi)  
Subzi Mandi, Delhi-110007

110001400037-2



*Nidhi*  
Nidhi Gupta  
Technical Manager  
Checked by

*Souraj*  
Souraj Gautam  
Microbiologist  
Authorized Signatory

*Dr Shival Singh*  
Dr Shival Singh  
Director Technical  
Authorized Signatory



NOTES: (1) The laboratory accepts the responsibility for content of report. (2) The above result pertain only to the sample tested and applicable parameters. (3) Test report shall not be reproduced except in full, without written approval of the laboratory. (4) This test report shall not be reproduced wholly or in part and can not be used as an evidence in the court of law without written approval of M/S AGSS. (5) The sample will be stored up to 21 days from the date of issue of test